



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7301CS0443

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	CCT Inox S.p.A. Via Udine, 95, I-20010 Canegrate (MI)
Distributor <i>Vertreiber</i>	CCT Inox S.p.A. Via Udine, 95, I-20010 Canegrate (MI)
Product Category <i>Produktart</i>	Stainless tubes: Stainless steel tube (7301)
Product description <i>Produktbezeichnung</i>	Longitudinally welded stainless steel pipe for drinking water installation
Model <i>Modell</i>	CCT
Test reports <i>Prüfberichte</i>	Supplement test: 20250723 from 23.07.2025 (TTR) Laboratory control test: 1112462-001 from 20.12.2022 (TTR) Supplement test: 20191105 from 05.11.2019 (TTR) Type testing: 20180412 from 12.04.2018 (TTR) Supplement test: 20180131 from 31.01.2018 (TTR) Type testing: 20171213 from 13.12.2017 (TTR)
Test basis <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	13.12.2027 / 25-0422-WNR

7028-04-A-DE

01.08.2025 Swd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
CCT	Manufacturing group: 15 bis 76,1 mm	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

tested dimensions (GW 541: table 3, EN 10312: series 2); material: 1.4404

15,0 x 1,0 mm, 18,0 x 1,0 mm, 22,0 x 1,2 mm, 28,0 x 1,2 mm, 28,0 x 1,5 mm, 35,0 x 1,5 mm, 42,0 x 1,5 mm, 54,0 x 1,5 mm and 76,1 x 2 mm

tested dimensions (GW 541: Table 3, EN 10312: Series 2); material: 1.4521

15,0 x 1,0 mm, 18,0 x 1,0 mm, 22,0 x 1,2 mm, 28,0 x 1,2 mm, 35,0 x 1,5 mm, 42 x 1,5 mm, 54,0 x 1,5 mm

The hygienic safety of all materials that come into contact with drinking water has been proven.